



**CLASSIFICATION REPORT NO. 18/03-A134-K1**

Version 1.en

Testing of balcony glazing with reference to the test standards EN 1026 for air permeability  
EN 12211 for resistance to wind load and DIN EN 13049 for impact resistance

**Applicant** Emre Al. Yapı Sanayi Tic.A.Ş.  
Adem yavuz mah. Ali yüksel sok. No:37  
Ümraniye – İstanbul

**Type** Fully glazed sliding balcony glazing system with fixed bottom glazed panels  
made of double glazing

**Product designation** **Panorama Thermal**

**Dimensions** Total outside dimensions (W x H): max. 2000 x 2000 mm  
Each panel dimensions (W x H): max. 1820 x 630 mm

**Classification** According to test report No. 18/03-A134-B1

EN 1026	<b>Air permeability</b> based on total area according to joint length <b>final classification</b>	EN 12207 EN 12207 EN 12207	Class 3 Class 2 Class 3
EN 12211	<b>Resistance to wind load</b>	EN 12210	Class <b>C1/B2</b>
EN 13049	<b>Impact resistance</b> <b>Impact from inside</b> <b>Impact from outside</b>	EN 13049 EN 13049	Class <b>5</b> Class <b>4</b>

Measurement uncertainties were not included in the classification.

**Validity** Valid for the validity period of EN 14351-1 : 2006 + A2 : 2016

Dipl.-Ing. Matthias Demmel  
Deputy Head of Test Body

Stephanskirchen  
25.01.2024

Dipl.-Ing. (FH) Christoph Geiger  
Responsible Official

**PfB GmbH & Co. Prüfzentrum für Bauelemente KG**

Ein Unternehmen der TÜV NORD GROUP